



WESTSIDE:	EASTSIDE:
2 FIRST AVENUE	71 MERCER STREET
OSWEGO NY 13126	OSWEGO, NY 13126
PHONE: (315) 342-3777	PHONE: (315) 342-2500
FAX: (315) 342-8233	FAX: (315) 342-8233

May 1, 2019

Subject: City of Oswego CSO Public Notification Annual Report

In accordance with USEPA document entitled "Public Notification Requirements for Combined Sewer Overflows to the Great Lakes Basins" the City of Oswego respectfully submits an annual report for 2018. This rule requires that POTWs in the Great Lakes Basin with CSOs document the Public Notification procedures they follow. The City of Oswego is to provide an annual report summarizing CSO events for 2018 for the Riverwalk, Excess Flow Management Facility (EFMF), westside outfall 004 to Gardiner Creek and Eastside WWTP Detention Basin.

This report includes two tables. Table 1 summarizes all CSO events for 2018 including date, location, duration, volume, precipitation and whether event occurred during dry or wet weather. Table 2 summarizes all analytical data from permitted overflows as required by the SPDES permit for that CSO outfall.

During 2018 there were 13 CSO events reported to the public from three outfalls. There were four overflows from Westside Gardiner Creek outfall 004 and five from Westside EFMF outfall 002. There were 4 overflows from Eastside Detention Basin outfall 002. Overflows through EFMF and Detention Basin facilities met the 9 minimum control standards. The City continues work on the system to further alleviate the number and severity of overflows.

Sincerely,

Kenneth Scherrieble

Superintendent

**TABLE 1
CSO PUBLIC NOTIFICATION ANNUAL REPORT
NY0029106**

DATE	LOCATION	DURATION	VOLUME	WEEKLY RAINFALL/ SNOWMELT	CAUSE
1/11/18	WEST 004 BYPASS	50 h 32 m	23,140,000 GALS	1.58" + 3' of snow melt	WET WEATHER
1/11-13/18	EFMF 002	50 h	24.47 MGD	1.58" + 3' of snow melt	WET WEATHER
1/23/18	EFMF 002	15h 40 min.	0.76 MGD	0.52"	WET WEATHER
10/2/18	EFMF 002	6 h	1.20 MGD	6.46"	WET WEATHER
11/9/18	WEST 004 BYPASS	2 h 15 m	22,000 GALS	1.3"	WET WEATHER
11/27/18	WEST 004 BYPASS	20 h 7 m	180,000 GALS	2.3"	WET WEATHER
11/27/18	EFMF 002	31 h	2.0 MGD	2.3"	WET WEATHER
12/22/18	WEST 004 BYPASS	18 h 10 m	106,000 GALS	1.54"	WET WEATHER
12/22/18	EFMF 002	18 h	1.75 MGD	1.54"	WET WEATHER

**CSO PUBLIC NOTIFICATION ANNUAL REPORT
NY0029114**

DATE	LOCATION	DURATION	VOLUME	WEEKLY RAINFALL/ SNOWMELT	CAUSE
1/11-13/18	002 DB	50 h	9.5 MGD	1.58" + 3' of snow melt	WET WEATHER
1/23/18	002 DB	15 h	0.6 MGD	0.52"	WET WEATHER
11/28/18	002 DB	31 h	1.7 MGD	2.3"	WET WEATHER
12/22/18	002 DB	10 h 20 m	0.5 MGD	1.54"	WET WEATHER

TABLE2**2018 Westside Excess Flow Management Data Summary (outfall 002)**

Date	Influent TSS	Influent BOD	Effluent TSS	Effluent BOD	Oil & Grease
1/11/2018	22	<20	23.6	30.6	<5
1/23/2018	30	15	3.8	<2	<5
10/2/2018	101	<70.8	114	<35.4	<5
11/28/2018	38	22.2	12	22.9	<5
12/22/2018	32	27	18	20	<5

2018 Eastside Detention Basin Data Summary (outfall 002)

Date	Influent TSS	Influent BOD	Effluent TSS	Effluent BOD	Oil & Grease	Fecal Coliform
1/11/2018	108	70.3	27.6	24	<5	96
1/23/2018	17	21.3	5.8	15.2	<5	2
11/28/2018	48	22.4	12	20.6	<5	49
12/22/2018	620	40	30	8.6	<5	59