

SECTION 1

New York State Department of Environmental Conservation
Division of Water

1W

Report Noncompliance Event

To: DEC Water Contact: Val Murakami DEC Region: 7
Report Type: 5 day Permit Violation Order Violation Anticipated Noncompliance X Bypass/Overflow Other

SECTION 2

SPDES #: NY-- 0029106 Facility: Westside Wastewater Treatment Plant
Date of noncompliance: 2/5/19 Location (Outfall, Treatment Unit, or Pump Station): Outfall WWTP-SSO #004
Description of noncompliance(s) and cause(s): Bypass of sanitary sewer wastewater occurred through unpermitted Outfall #004
Due to high flows caused by snow melt Chief Operator was attempting to maximize plant capacity by adjusting influent gate.
Influent gate was lowered too far and caused the momentary bypass.

Has event ceased? (Yes) (No) If so, when? 1/5/19 Was event due to plant upset? (Yes) (No) SPDES limits violation (Yes) (No)
Start date, time of event: 2/5/19 11:30 (AM)(PM) End date, time of event: 1/5/19 11:45 (AM) (PM)
Date, time oral notification made to DEC? 2/5/19 10:45 (AM) (PM) DEC Official contacted: Val Murakami
Immediate corrective actions: Influent gate was re-adjusted to its former position and overflow ceased

Preventive (long term) corrective actions: Ongoing separation projects of the Westside Collection system are on schedule as per consent decree.

SECTION 3

Complete this section if event was a bypass:

Bypass amount: 1,000 gals Was prior DEC authorization received for this event? (Yes) (No)
DEC Official contacted: _____ Date of DEC approval _____

Describe event in "Description of noncompliance and cause" area in Section 2. Detail the start and end dates and times in Section 2 also.

SECTION 4

Forms by EnviroWin (312-244-1900)

Facility Representative John McGrath Title: Chief Operator Date: 2/5/19

Phone #: 315 342-3777 Fax # 315 342-8233

3506-101 (12/93)

Signature: John W. McGrath